

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7770-0328:0524

Page 1 of 1

CATEGORY: 7770 -- VALVES/SWITCHES

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042 United States
Contact: Michael McIsaac (314) 628-2218 Fax (314) 595-6999
Email: michaelm@pottersignal.com

DESIGN: Models PIBV2 and OSY2 Valve Supervisory Switches. Products are supervisory actuating devices for use in conjunction with a sprinkler supervisory, waterflow alarm system. Model OSY2 is intended for use with gate valves of the open stem and yoke type for indicating total or partial closure of the valve and Model PIBV2 is intended for use with post indicator valves of the flag type. Also suitable for outdoor use.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 125/250 VAC, 10 A; 24 VDC, 2.5 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as valve supervisory switches for use in fire sprinkler systems. Also suitable for outdoor use. Refer to listee's Installation Instruction Manual for details.

NOTE: Formerly 7770-1653:0118

8-9-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division