

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7770-0328:0525

Page 1 of 1

**CATEGORY:** 7770 -- VALVES/SWITCHES

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042 United States  
Contact: Michael Mclsaac (314) 628-2218 Fax (314) 595-6999  
Email: michaelm@pottersignal.com

**DESIGN:** Models EPS10-1, EPS10-2, EPS40-1, EPS40-2, EPS120-1, and EPS120-2 Pressure Switches. Suffixes -1 and -2 indicate number of switches. Intended for use indoors or outdoors in a dry or wet pipe system to detect a change in pressure.

Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 125/250 VAC, 10 A; 24 VDC, 2.5 A

Pressure Range:

EPS10-1, -2: 4-20 psi

EPS40-1, -2: 10-100 psi

EPS120-1, -2: 10-200 psi

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, pressure range, and UL label.

**APPROVAL:** Listed as pressure switches for use in dry or wet pipe fire sprinkler systems. Suitable for indoor or outdoor use. Refer to listee's Installation Instruction Manual for details.

**NOTE:** Formerly 7770-1653:0117

8-2-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**  
*Fire Engineering Division*