



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7770-0328:0525
<b>CATEGORY:</b>	7770 - VALVES/SWITCHES
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
<b>DESIGN:</b>	Models EPS10-1, EPS10-2, EPS40-1, EPS40-2, EPS120-1, and EPS120-2 Pressure Switches. Suffixes -1 and -2 indicate number of switches. Intended for use indoors or outdoors in a dry or wet pipe system to detect a change in pressure.  Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	125/250 VAC, 10 A; 24 VDC, 2.5 A  Pressure Range: EPS10-1, -2: 4-20 psi EPS40-1, -2: 10-100 psi EPS120-1, -2: 10-200 psi
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, pressure range, and UL label.
<b>APPROVAL:</b>	Listed as pressure switches for use in dry or wet pipe fire sprinkler systems. Suitable for indoor or outdoor use. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	Formerly 7770-1653:0117

8-2-21 VWW



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/02/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division