



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7770-0328:0526
CATEGORY:	7770 - VALVES/SWITCHES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	Models WFDNFS and WFDNFT Paddle Type Waterflow Indicators. Model WFDNFS intended for installation in CPVC tee fitting employing a slip fit adapter and Model WFDNFT intended for installation in CPVC threaded tee fitting. Pipe sizes 1", 1-1/4", 1-1/2", and 2". Suitable for indoor and outdoor environments. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	Maximum Working Pressure: 175 psig Terminal Block Micro Switch: 125/250 VAC, 10 A; 24 VDC, 2.5 A Enclosure Rating: NEMA Type 4
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and UL label.
APPROVAL:	Listed as waterflow indicators for use in wet pipe fire sprinkler systems. Suitable for indoor and outdoor environments. Refer to listee's Installation Instruction Manual for details.
NOTES:	Formerly 7770-1653:0501

8-3-21 VWW



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/02/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division