



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7770-0328:0528
CATEGORY:	7770 - VALVES/SWITCHES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	Models EPS10EXP, EPS40EXP, and EPS120EXP Pressure Switches. Intended for use indoors or outdoors in a dry or wet pipe system to detect a change in pressure. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	125/250 VAC, 10 A; 24 VDC, 2.5 A Pressure Range: EPS10EXP: 4-20 psi EPS40EXP: 10-100 psi EPS120EXP: 10-200 psi
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, pressure range, and UL label.
APPROVAL:	Listed as pressure switches for use in dry or wet pipe fire sprinkler systems. Intended for use indoors or outdoors. Suitable for use in Class I, Groups B, C, and D; Class II, Groups E, F, and G hazardous locations. Refer to listee's Installation Instruction Manual for details.
NOTES:	Formerly 7770-1653:0146

8-10-21 VWW



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/02/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division