



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7770-0328:0530
CATEGORY:	7770 - VALVES/SWITCHES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	<p>Model PSP1 Plug-in Special Purpose Valve Supervisory Switch. This unit is not intended or designed for ordinary use. It is a special application device to be used for unusual conditions, such as pit valves and pumping sites, non-rising stem gate valves where no other approved method of protection is available or practical. Also suitable for outdoor use.</p> <p>Refer to listee's data sheet for additional detailed product description and operational considerations.</p>
RATING:	<p>24 VAC/VDC, 250 mA</p> <p>Enclosure Rating: NEMA 3</p>
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and UL label.
APPROVAL:	Listed as a valve supervisory switch for use in special applications only. Not intended or designed for ordinary uses or in fire protection systems. Refer to listee's Installation Instruction Manual for details.
NOTES:	<p>1. As this unit does not meet NFPA Standards, requiring restoration signal when the valve is positioned to normal, special attention should be given by the responsible parties to assure that the proper operation of this device is maintained. This device should only be restored to normal when the valve is in normal condition.</p> <p>2. Formerly 7770-1653:0170</p>



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

8-26-21 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/02/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division